

IPLV - Northmore Gordon

Canonical: <https://northmoregordon.com/glossary/iplv/>

Details:

[Home](#) › [Glossary](#) › IPLV

IPLV

IPLV stands for Integrated Part-Load Value, as defined in the Northmore Gordon glossary. It is a performance metric used to assess equipment efficiency across varying operating conditions, rather than at a single rated capacity. This metric is particularly relevant for systems like refrigeration and HVAC that operate at different load levels throughout their operating cycle, making part-load performance a critical factor in real-world energy consumption and cost forecasting.

Related guidance

[Carbon advisory](#)

[Scope 1, 2 and 3 emissions](#)

[Certificates](#)

[Government schemes](#)

[Certificate trading](#)

[Measurement and verification](#)

What does IPLV stand for?

IPLV stands for Integrated Part-Load Value, as defined in the Northmore Gordon glossary. It is a performance metric used to assess equipment efficiency across varying operating conditions, rather than at a single rated capacity. This metric is particularly relevant for systems like refrigeration and HVAC that operate at different load levels throughout their operating cycle, making part-load performance a critical factor in real-world energy consumption and cost forecasting.

Why is IPLV important for energy efficiency assessment?

IPLV is important because equipment rarely operates at its nominal or rated capacity. Systems typically run at partial load for extended periods, and part-load efficiency often differs significantly from rated-capacity performance. Understanding IPLV helps identify the actual energy consumption patterns and operational costs across a facility's real load ranges. This understanding supports more accurate investment cases and measurement and verification outcomes when comparing equipment options or forecasting project savings.

How does IPLV relate to refrigeration and HVAC system design?

IPLV is essential for designing refrigeration and HVAC systems that will operate efficiently under actual facility conditions. Rather than selecting equipment based solely on peak capacity needs, IPLV assessment guides the choice of compressors, controls and sequencing to maintain efficiency when cooling or heating demand is below maximum. Our energy audits and system-performance evaluations incorporate part-load analysis to ensure selected equipment matches the facility's typical operating profile and delivers both reliability and cost effectiveness.

What is the difference between nominal efficiency and IPLV?

Nominal efficiency is the rated efficiency of new equipment as specified by the manufacturer, typically measured at full load or a standard test condition. IPLV, by contrast, reflects weighted efficiency across multiple partial-load scenarios, providing a more realistic picture of annual energy consumption. For equipment decisions, nominal efficiency alone can underestimate actual operating costs. Our assessment framework considers both metrics to support robust procurement and investment decisions that account for real-world operating conditions.

How should IPLV influence equipment procurement and replacement decisions?

IPLV should inform procurement by prioritizing equipment that maintains good efficiency across the expected load range, not just at peak capacity. When evaluating compressors, chillers or HVAC units for replacement, a Type 3 precision assessment should review capacity, controls and sequencing before purchase decisions are made. Including IPLV in the technical specification helps ensure selected equipment will deliver forecasted energy savings under actual operating conditions. We provide utility benchmarking and feasibility assessment to guide these procurement choices with credible part-load performance data.

How does IPLV connect to measurement and verification of energy savings?

Part-load performance and IPLV are relevant to establishing baselines and forecasting post-project consumption in measurement and verification. If a system operates primarily at partial load, the baseline model must account for that operating pattern. Post-upgrade comparisons should use representative operating periods that reflect typical load variation rather than peak conditions. Our M&V services include baseline modelling that incorporates part-load performance to establish credible savings evidence and ensure that measurement boundaries and adjustments appropriately reflect how systems actually operate.

What information is needed to assess IPLV for an existing system?

Assessing IPLV for an existing system requires equipment details such as capacity and age, operating load profiles across representative periods, maintenance history, and records of how conditions vary seasonally or by production shift. Energy data showing consumption under different operating conditions supports realistic part-load analysis. Our energy audits and energy-use investigations gather this information through utility benchmarking, metering and monitoring, and analysis of bills and interval data to establish how equipment performs across its actual load ranges.

Can IPLV improve the business case for equipment upgrades?

Yes. When a system operates predominantly at part load, upgrading to equipment with better IPLV performance can deliver larger energy savings than equipment selected solely on nominal efficiency. This stronger savings case can improve project economics and influence funding decisions. Our investment case guidance includes part-load analysis and realistic operating-scenario modelling to support comparison of upgrade alternatives. Clear documentation of load profiles and IPLV benefits also strengthens applications for environmental certificates or grant support where energy savings are a key criterion.